



XHBN.WW-D-1220 - JOINT SYSTEMS

Design/System/Construction/Assembly Usage Disclaimer

- Authorities Having Jurisdiction should be consulted in all cases as to the particular requirements covering the installation and use of UL Certified products, equipment, system, devices, and materials.
- Authorities Having Jurisdiction should be consulted before construction.
- Fire resistance assemblies and products are developed by the design submitter and have been investigated by UL for compliance with applicable requirements. The published information cannot always address every construction nuance encountered in the field.
- When field issues arise, it is recommended the first contact for assistance be the technical service staff provided by the product manufacturer noted for the design. Users of fire resistance assemblies are advised to consult the general Guide Information for each product category and each group of assemblies. The Guide Information includes specifics concerning alternate materials and alternate methods of construction.
- Only products which bear UL's Mark are considered Certified.

XHBN - Joint Systems XHBN7 - Joint Systems Certified for Canada

See General Information for Joint Systems

See General Information for Joint Systems Certified for Canada

System No. WW-D-1220

May 16, 2019

ANSI/UL2079


CAN/ULC S115

Assembly Ratings —1 Hr	F Ratings —1 Hr
Nominal Joint Width — 2- 1/4 to 6 In.	FT Ratings —1 Hr
Class II or III Movement Capabilities — 50% Compression or Extension	FH Ratings —1 Hr
	FTH Ratings —1 Hr
	Nominal Joint Width — 57 mm to 152 mm
Cookies on UL	Class II or III Movement Capabilities — 50% Compression or Extension

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners.. [Learn More](#)

› [Cookie Settings](#)

✓ [Accept](#)



1. Wall Assembly — The 1 hr fire rated framed gypsum wallboard wall assembly shall be constructed of the materials and in the manner specified in the individual U300, V300, U400, V400 or W400 Series Wall and Partition Designs in the UL Fire Resistance Directory and shall include the following construction features:

A. **Studs** — Steel studs to be min 3-5/8 in. (89 mm) wide and spaced max 24 in. (610 mm) OC. Wood studs to be 2 by 4 in. (38 by 89 mm) lumber spaced max 16 in. (406 mm) OC.

B. **Gypsum Board*** — Gypsum board to be installed to a min total thickness of 5/8 in. (16 mm) on each side of wall and on each stud face within joint opening.

2. Joint System — Nominal width of joint is 2-1/4 to 6 in. (57 to 152 mm). The joint system is designed to accommodate a max 50 percent compression or extension from its installed width. The joint system shall consist of the following:

A. **Mechanical Joint Assembly*** — Compressed, fire-retardant impregnated, 3-3/4 in. (95 mm) deep foam coated on each side with silicone. Foam is installed in joint opening as a permanent form.

EMSEAL L L C — WFR1 Mechanical joint system.

Cookies on UL

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners. [Learn More](#)

B. **Sealant Band** — (Optional) — Watertight 3/4 in. (19 mm) deep silicone sealant band and corner bead supplied by joint system manufacturer, and installed in accordance with installation instruction.

C. **Epoxy adhesive** — Consists of two parts; part A (base), and part B (hardener). The epoxy is supplied by joint system manufacturer, and installed in accordance with installation instructions. [Cookie Settings](#)

✓ Accept

* Indicates such products shall bear the UL or cUL Certification Mark for jurisdictions employing the UL or cUL Certification (such as Canada), respectively.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"

Cookies on UL

We use cookies to personalize content and ads, to provide social media features and to analyze our traffic. We also share information about your use of our site with our social media, advertising and analytics partners.. [Learn More](#)

[> Cookie Settings](#)

✓ Accept